

901 Main Street P.O. Box 728 Geraldton, Ontario. POT 1M0 Fax: 807 854-0483

March 18, 2025

Ministry of the Environment 3rd Flr. Suite 331B, 435 James St. Thunder Bay, ON P7E 6S7

Attention: Mr. Glen Niznowski, District Manager

Re: 2024 Performance Report for Geraldton Wastewater Treatment Facility

Dear Mr. Niznowski:

Attached is the 2024 Performance Report for the **Geraldton Wastewater Treatment Facility** located on Clarke Avenue in The Corporation of the Municipality of Greenstone – Geraldton Ward. This report has been completed in accordance with Condition No. 10 (6) cited in *Certificate of Approval Number 0172-6E7JZP* dated 16th January 2006 and issued to the Corporation of the Municipality of Greenstone.

This report was prepared by the Ontario Clean Water Agency on behalf of the Corporation of the Municipality of Greenstone based on information kept on record by OCWA at the Geraldton WWTP, and, the report covers the period from January 1 2024 to December 31 2024.

Should you have any questions or comments in regards to this annual report, please do not hesitate to contact Dave Hoffman at 807-854-7142.

Yours truly,

PO'Handley

Patti O'Handley Senior Operations Manager Ontario Clean Water Agency Northwestern Ontario Hub

Copy: Mr. Mark Wright - CAO Mr. Brian Aaltonen – Director of Public Services Operations Staff – Geraldton Sam Shippam – MECP

2024 Annual Report

Geraldton Wastewater Treatment Plant

Prepared by the Ontario Clean Water Agency



The Corporation of the Municipality of Greenstone - Geraldton Wastewater Treatment Plant (Sewage Plant) 2024 Annual Report

INTRODUCTION

In accordance with the *Certificate of Approval Number 8151-7PDQX7* section 10 (6), the Corporation of the Municipality of Greenstone - Geraldton Wastewater Treatment Plant is required to prepare an annual summary. The 2024 annual facility performance report summarizes important information regarding the treatment quality of the effluent wastewater, analytical test results, relevant activities and maintenance operations of the Works. Some of this information was submitted via the quarterly upload of information, but is being presented again as part of the new Annual Report based on the calendar year.

DESCRIPTION OF WORKS

Rated Capacity of Works	2,500 m ³ /day
Service Area	Greenstone Municipality – Geraldton Ward, District
	of Thunder Bay
Service Population	1,150
Effluent Receiver	Hardrock Creek
Major Process	Extended Aeration Plant
	Includes separate Aeration Tanks and Final Clarifier

EFFLUENT MONITORING AND RECORDING

Analytical tests to monitor the influent and effluent water quality on a weekly/monthly basis are conducted by a laboratory audited by the Canadian Association for Environmental Analytical Laboratories (CAEAL) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods. Weekly analysis is performed in-house in order to maintain the process. When these samples are split with the accredited laboratories, it confirms the procedure accuracy of the in-house testing.

SAMPLING REQUIREMENTS

Samples of raw sewage and final effluent from the WWTP shall be collected and analyzed for the following parameters at the indicated frequencies.

Raw	Sewage	Monitori	ng – Sam	ples to b	e collected	at the tr	eatment r	olant ir	ılet
	Sen age				e concerea		carment I	<i></i>	

Parameters	Sample Type	Frequency
CBOD ₅	Composite*	monthly
Total Suspended Solids	Composite*	monthly
Total Phosphorus	Composite*	monthly
Total Kjeldahl Nitrogen*	Composite*	monthly

* Composite of three grab samples, taken at time intervals of at least two hours over an eight-hour sampling period.

Final Effluent Monitoring - Samples to be collected at the treatment plant outfall

Parameters	Sample Type	Frequency
CBOD ₅	Composite*	weekly
Total Suspended Solids	Composite*	weekly
Total Phosphorus	Composite*	weekly
Total Ammonia		
(Ammonia + Ammonium)	Composite	weekly
Nitrogen		
Un-ionized Ammonia	Calculated**	weekly
E. Coli	Grab	weekly
Total Chlorine Residual	Grab	weekly
pH	Grab	weekly
Temperature***	Grab	weekly

* Composite of three grab samples, taken at time intervals of at least two hours over an eight-hour sampling period.

** Calculated based on results of effluent total ammonia nitrogen, temperature and pH monitoring.

***Temperature of the final effluent should be measured in the field.

Creek Monitoring – Samples to be collected from Hardrock Creek; sampling locations subject to approval by the *District Manager* (MOE staff reviewed sampling locations in June & December 2007)

Monthly*
Grab
Temperature**, pH, Dissolved Oxygen, Total Suspended Solids, Total
Phosphorus, Total Ammonia Nitrogen, E. Coli

* Monthly during the ice-free period.

** Temperature should be measured in the field.

Lake Monitoring – Samples to be collected from Kenogamisis Lake; sampling locations subject to approval by the *District Manager* (MOE staff reviewed sampling locations in June & December 2007)

Frequency	Monthly*
Sample Type	Grab
Parameters	Temperature**, pH, Conductivity, Total Suspended Solids, Total
	Phosphorus, Total Ammonia Nitrogen, E. Coli

* Monthly during the ice-free period.

** Temperature should be measured in the field.

PLANT PERFORMANCE

Effluent Objectives (best effort) as per C of A, condition 6(1)

Effluent Parameter	Concentration Objective (milligrams per litre unless otherwise indicated)				
CBOD ₅	15.0 mg/L monthly average				
Total Suspended Solids	15.0 mg/L monthly average				
Total Residual Chlorine	Non-detectable*				
E. Coli	100 organisms/100 ml				
	(monthly Geometric Mean Density)				
Use best effort to operate works at rated capacity of $2.500 \text{ m}^3/\text{day}$					

* Non-detectable as measured by equipment with a sensitivity of at least 0.02 mg/L.

Effluent Objectives (shall operate) as per C of A, condition 7(1)

Effluent Parameter	Average Concentration					
	(milligrams per litre unless otherwise					
	indicated)					
CBOD ₅	25.0 mg/L monthly average					
Total Suspended Solids	25.0 mg/L monthly average					
Total Residual Chlorine*	Non-detectable*					
pH of the effluent maintained between 6.0 to 9.5, inclusive at all times						

* Non-detectable as measured by equipment with a sensitivity of at least 0.02 mg/L.

In order to review, at a glance, the performance of the WWTP, a graph has been prepared showing the average and maximum monthly raw influent flows for the year; January to

December 2024 The total influent flows for this timeframe report as 592,282, compared to $562,431m^3$ for the 2023 calendar year. This is an increase of 5 % over the 2023 flows.

In the reporting year 2024, *CBOD*⁵ was analyzed and the maximum monthly average was 39.44 mg/L in December; this is above the effluent limits imposed by the *Certificate of Approval* condition 1.4 of 25.0 mg/L. The maximum monthly average of daily loading was 66.353 kg/day for the month of December. This was above the effluent limit of 62.5 kg/day. The works did not achieve the effluent objective of 15.0 mg/L in 2024.

The maximum monthly average suspended solids concentrations for the effluent in 2024 was 33.98 mg/L for the month of December. This parameter is likewise above the compliance level of 25.0 mg/L. The maximum monthly average of daily loading was 61.694 kg/day for the month of April with a limit of 62.5 kg/day. The works did not achieve the effluent objective of 15.0 mg/L.

The plant compliance criteria states; the pH of the effluent shall be maintained between 6.0 and 8.5, inclusive, at all times. The average pH during this period was 6.70, with a high of 7.67 and a low of 5.80. The effluent from the works did not meet the compliance level for pH in 2024. Two dates of January 2024 had levels below 6.0, January 10 and 15. The cause of the low pH is unknown due to the isolated nature of the events.

The owner shall use best effort to operate the works within the rated capacity of 2,500 m³/d. Average flows from the plant were measured at 1618.26 m³/d with the maximum daily flow being 3209.60 m³/d; best effort was not achieved.

Condition Number 7 – Effluent Limits - of the Certificate of Approval outlines, in part, the following that the:

Total Residual Chlorine*	Non-detectable*

* Non-detectable as measured by equipment with a sensitivity of at least 0.02 mg/L.

The average chlorine residual for 2024 was 0.76 mg/L, max 2.02 mg/L before de-chlorination. After de-chlorination, the chlorine residual was 0.10 mg/l maximum. The table of chlorine residuals and effluent chlorine residuals is attached.

The effluent parameter include a best effort monthly geometric mean density of 100 organisms per 100 ml for e-coli and a monthly geometric mean density limit of 200 organisms per 100 ml. In 2024 the maximum monthly geometric mean density for e-coli was 83 organisms per 100 ml. This achieved the limit criteria. The best effort monthly geometric mean was also achieved for 2024.

EFFLUENT FLOWS

The secondary treatment system is designed to operate at a *rated capacity* not to exceed the peak flow rate of $7,500m^3/d$ for the sewage treatment plant. For the Geraldton Wastewater Treatment Plant the peak flow for 2024 was on April 12 with a peak flow of 3209.6 m³/day. Currently, the

Geraldton wastewater treatment *Certificate of Approval* outlines that the average daily flows of sewage into the sewage treatment plant does not exceed 2,500.m³/d. The average daily flow for 2024 was 1618.26 m³/d.



Average & Maximum Flows January – December 2024

MAINTENANCE

OCWA maintains a Work Management System (WMS), which is a comprehensive computer based maintenance program that is based on a proactive preventive approach. This includes running checks, weekly, monthly and annual maintenance, as required. A full report on all maintenance carried out in 2024 is available upon request.

OPERATIONAL ISSUES

The Geraldton WWTP has experience facility issues in relation to the past upgrades.

In the engineers' opinion, bypassing was a result of excessive inflow and infiltration into the collection system. They recommend the municipality investigate the sources of the inflow and infiltration and reduce these sources to control the bypasses in the system.

The municipality has initiated a Pollution Prevention Control Plan which included an inflow and infiltration study. The results of this study were received in 2013. Several yard drains and broken/ open services were identified as were some downspout connections. The yard drains and broken/ open services were repaired by the municipal crews. Homes with downspout connections were sent notifications by the municipality to remove the downspout connections. The municipality has received confirmation that some have been corrected.

During 2024 the yearly flows to the sewage plant was relatively normal. The summer was dry and resulted in reduced flows to the plant during a significant part of the summer. The peak flows occurred during the spring melt during April and May. The high inflow rate exceeded the 87 L/sec, rate to the plant resulting in a bypass on April 11.

The sewage plant is designed to bypass at an inflow of 87 l/sec. There was one event of bypassing in 2024 reported. The event occurred at the treatment plant due to the incoming flows exceeding 87 l/sec. The event occurred on April 11 2024 and lasted for 12 hours resulting in 465 m3 bypassing the treatment process. The bypassing occurred intermittently over the time period as the flows spiked during the spring melt. The increased flows also resulted in an operational upset in the facility. The TSS was over the 25 mg/l average for the month. The alum system was not adjusted quickly enough during the increased flows.

The sewage plant had a major mechanical failure on December 3 2024. The gear box for the clarifier failed. The spare gear box on site did not fit the clarifier. The repair parts were sourced and ordered for the failed gear box. The repairs will be completed once the parts are onsite. A pump has been installed in the clarifier to keep the sludge moving and the tank from freezing. The failure has resulted in the TSS and CBOD being over the compliance levels in December.

The conversion of the idle aeration chamber into sludge storage did not perform as designed. The aeration chamber is not being used for sludge storage at this time and will remain out of service. The aeration chamber was used in 2024 to capture and hold excess raw sewage inflow to the plant to reduce bypassing. The tank was filled to capacity during the April and May bypassing events prior to bypassing the plant process. The captured influent was then pumped back through the treatment process when the plant inflow decreased.

The aeration tank for Plant #1 was cleaned and inspected in 2018. Cracks were observed in the floor of the tank. These cracks may need repair in the future.

Greenstone Gold Mines completed opening a mine close to Geraldton. As a result, the municipality has upgraded the sewage treatment plant for the anticipated additional flows. The engineering and approval processes are proceeding and a new ECA is expected early in the New

Year. A temporary alum system was installed and operating at the treatment plant for phosphorus control. Modifications are complete on the site with the installation of the permanent alum system and tank to mitigate bypass events. The permanent alum system was commissioned in December 2023. Presently there is no pace to flow feed system and the operators adjust feed rates based on historic flows. The equalization tank used for bypass events is being commissioned.

The mine has temporary camp facilities with the generated sewage being hauled to facilities for treatment. The sewage was hauled to the Geraldton and the Nakina wastewater facility in 2024. The trucked waste is introduced into the collection system at the McKenzie lift station. During 2024, the system accepted 9050 m3 of raw sewage from the temporary mine camp. This equates to an average of 49.2 m3 per day of raw sewage to the collection system.

There were complaints received by the MECP in September and October concerning the odors from the dumping of the sewage into the collection system at the McKenzie lift station. Discussion with the mine concerning the holding tank at the camp included more frequent cleaning and mixing of the tank. The results of that activity are still being assessed as the cold weather was expected to decrease odor as well.

CALIBRATIONS

The owner shall maintain a continuous flow-measuring device to measure the flow rate within an accuracy of +/-5% of actual rate of flow within the range of 10% to 100% of the full-scale reading of the measuring devices.

In 2024, calibration of the Miltronics continuous measuring device was calibrated by a Lakeside technician; results attached. The units were within the required accuracy, as outlined in the criteria.

SLUDGE SUMMARY

Sludge is hauled from the facility to the Nakina and Longlac drying beds by the Ontario Clean Water Agency. A summary of all sludge hauled for Geraldton WWTP is outlined in the following table.

Month	Total Volume(m3)
January	195
February	255
March	165
April	90
May	495
June	255
July	210
August	225

Sludge Volume Hauled in 2024

September	285
October	150
November	195
December	0
Total	2520
I Utal:	2520

The new sludge beds at Octopus Lake were tried in the past and failed. The beds were modified for use again and in early 2013 the beds were put into service and operated through the year. The Octopus beds performed better in 2015. The bed drainage system was excavated for inspection/ repair to improve drainage. The MECP requested an evaluation of the sludge bed in 2021. During 2022 an inspection of the beds by the MECP found seepage outside of the bed construction. The beds have not been used for sludge drying since while the municipality investigates corrective actions to repair the beds or an alternate drying location. The sludge generated by the facility is presently being trucked to the Nakina or Longlac sludge drying beds for drying.

COMPLAINTS/ENVIRONMENTAL INCIDENT

There were complaints received by the MECP in September and October concerning the odors from the dumping of the sewage into the collection system at the McKenzie lift station.

BY-PASS REPORTS

The sewage plant is designed to bypass at an inflow of 87 l/sec. There was one event of bypassing in 2024 reported. The event occurred at the treatment plant due to the incoming flows exceeding 87 l/sec. The event occurred on April 11 2024 and lasted for 12 hours resulting in 465 m3 bypassing the treatment process. The bypassing occurred intermittently over the time period as the flows spiked during the spring melt. The increased flows also resulted in an operational upset in the facility. The TSS was over the 25 mg/l average for the month. The alum system was not adjusted quickly enough during the increased flows.

The sewage plant had a major mechanical failure on December 3 2024. The gear box for the clarifier failed. The spare gear box on site did not fit the clarifier. The repair parts were sourced and ordered for the failed gear box. The repairs will be completed once the parts are on-site. A pump has been installed in the clarifier to keep the sludge moving and the tank from freezing. The failure has resulted in the TSS and CBOD being over the compliance levels in December.

Performance Assessment Report 1st January – December 31st 2024



Performance Assessment Report

From 1/1/2024 to 12/31/2024 11:59:59 PM

02/27/2025

Page 1 of 1

5896 GERALDTON WASTEWATER TREATMENT	FACILITY 110	001649														
	1/2024	2/ 2024	3/ 2024	4/ 2024	5/ 2024	6/ 2024	7/ 2024	8/ 2024	9/ 2024	10/ 2024	11/ 2024	12/ 2024	<total></total>	<avg></avg>	<max></max>	<-Criteria->
Flows																
Eff. Flow: Total - Effluent m³/d	33,061.10	31,671.90	32,866.00	59,005.80	61,505.60	56,421.20	54,432.10	60,857.30	42,828.70	48,592.70	58,885.60	52,154.00	592,282.00		1	0.00
Eff. Flow: Avg - Effluent m³/d	1,066.49	1,092.13	1,060.19	1,966.86	1,984.05	1,880.71	1,755.87	1,963.14	1,427.62	1,567.51	1,962.85	1,682.39		1,618.26		
Eff. Flow: Max - Effluent m³/d	1,349.00	1,491.00	1,261.00	3,209.60	2,583.00	2,777.60	2,550.60	3,088.90	1,770.00	1,903.00	2,513.00	2,278.40			3,209.60	0.00
Eff Flow: Count - Effluent m³/d	31.00	29.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	366.00			0.00
Carbonaceous Biochemical Oxygen Demand: CBOD	1	II_I				III	LIL.,	J		IIL_I		4		الــــــــــــــــــــــــــــــــــــ		
Raw: Avg cBOD5 - Influent mg/L	92.40	62.00	63.40	98.20	23.60	96.70	20.50	69.80	62.70	88.30	106.00	129.00		76.05	129.00	0.00
Raw: # of samples of cBOD5 - Influent	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg cBOD5 - Effluent mg/L	5.14	4.95	10.10	23.97 <	2.05 <	2.18 <	2.34 <	2.00 <	2.00 <	3.96	3.53	39.44		9.36	39.44	25.00
Eff: # of samples of cBOD5 - Effluent	5.00	4.00	4.00	6.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			0.00
Loading: cBOD5 - Effluent kg/d	5.482	5.406	10.708	47.139 <	4.067 <	4.091 <	4.109 <	3.926 <	2.855 <	6.207	6.919	66.353		15.15	66.35	62.500
Percent Removal: cBOD5 - Influent %	94.44	92.02	84.07	75.59	91.31	97.75	88.59	97.13	96.81	95.52	96.67	69.43		89.94	97.75	0.00
Total Suspended Solids: TSS	<u>المعالم المعالم المعا</u>			·			L1LJ					1		·		
Raw: Avg TSS - Influent mg/L	66.00	67.80	65.50	48.70	39.10	109.00	30.30	102.00	77.40	71.60	122.00	112.00	1	75.95	122.00	0.00
Raw: # of samples of TSS - Influent	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg TSS - Effluent mg/L	7.92	8.88	13.85	31.37	7.63	6.58 <	4.48	5.05 <	4.35 <	5.08 <	4.25	33.98		12.00	33.98	25.00
Eff: # of samples of TSS - Effluent	5.00	4.00	4.00	6.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			0.00
Loading: TSS - Effluent kg/d	8.447	9.693	14.684	61.694	15.128	12.366 <	7.866	9.914 <	6.210 <	7.963 <	8.342	57.168		19.41	61.69	62.500
Percent Removal: TSS - Influent %	88.00	86.91	78.85	35.59	80.50	93.97	85.21	95.05	94.38	92.91	96.52	69.66		83.13	96.52	0.00
Total Phosphorus: TP	JII	1		1		I	II		I			I	1	I	1	
Raw: Avg TP - Influent mg/L	2.41	2.45	2.91	2.76	1.22	2.47	1.32	2.15	2.14	2.26	2.82	3.02	l.	2.33	3.02	0.00
Raw: # of samples of TP - Influent	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg TP - Effluent mg/L	0.33	0.32	0.49	0.74	0.16	0.14	0.15	0.15	0.23	0.33	0.36	1.18		0.40	1.18	
Eff: # of samples of TP - Effluent	5.00	4.00	4.00	6.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			0.00
Loading: TP - Effluent kg/d	0.354	0.348	0.519	1.453	0.318	0.260	0.256	0.290	0.331	0.521	0.709	1.980		0.65	1.98	
Percent Removal: TP - Influent %	86.22	87.00	83.19	73.24	86.84	94.39	88.96	93.13	89.17	85.30	87.19	61.03		84.64	94.39	0.00
Nitrogen Series	JIJLJ					III	L		II			1		и — Ц		
Raw: Avg TKN - Influent mg/L	22.00	23.20	25.00	26.00	10.90	21.10	12.20	21.10	21.20	26.00	28.60	26.80		22.01	28.60	0.00
Raw: # of samples of TKN - Influent	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg TAN - Effluent mg/L	6.58	6.59	8.47	6.10	4.61	0.24	0.92	0.07	0.22	0.81	0.11	9.99		3.88	9.99	
Eff: # of samples of TAN - Effluent	5.00	4.00	4.00	6.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			0.00
Loading: TAN - Effluent kg/d	7.013	7.194	8.977	11.995	9.142	0.456	1.615	0.144	0.312	1.275	0.215	16.807		6.27	16.81	

pH Monthly Process Data Report

Customized Monthly Report

From 01/01/2024 to 12/31/2024

Facility Name: GERALDTON WASTEWATER Municipality of Greenstone Receiver: Hardrock Creek to Kenogamisis Lake

TREATMENT FACILITY

Facility Org Number: 5896 Facility Owner: Municipality: The Corporation of the

Works: 110001649 Facility Classification: Class 2 Wastewater Treatment Total Design Capacity: 2500 m3/day



																			202	4		
Efflu	Jent	1	Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Π	Jun 2024	Jul 2024	Aug 2024	Sep 202	4	Oct 2024	Nov 2024	Dec	2024	Total	Avg		Max	Min
,	pH																					
	IH Month.Max		7.45	6.65	7.26	7.52	7.67	Π	7.30	7.29	7.15	7.20		6.99	6.69	6	95				7.67	
	IH Month.Mean		6.34	6.36	6.75	7.02	7.11	Π	6.97	6.99	6.72	6.38		6.51	6.55	6	64		6.70			
	IH Month.Min		5.80	6.01	6.35	6.35	6.20		6.62	6.47	5.92	6.06		6.12	6.45	6	37					5.80

Cl₂ Residual Monthly Process Data Report

Customized Monthly Report

From 01/01/2024 to 12/31/2024

Facility Name: GERALDTON WASTEWATER Municipality of Greenstone Receiver: Hardrock Creek to Kenogamisis Lake

TREATMENT FACILITY

Facility Org Number: 5896 Facility Owner: Municipality: The Corporation of the

Works: 110001649 Facility Classification: Class 2 Wastewater Treatment Total Design Capacity: 2500 m3/day

Ontario Clean Water Agency Agence Ontarienne Des Eaux

															2024		
Dec	hlorination	Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	Cl Residual: Total - mg/L																
	IH Month.Max	0.03	0.03	0.00	0.03	0.10	0.05	0.04	0.08	0.08	0.06	0.05	0.08			0.10	
	IH Month.Mean	0.01	0.01	0.00	0.01	0.02	0.01	0.02	0.04	0.03	0.02	0.03	0.03		0.02		
	IH Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.01	0.00				0.00
															2024		
Disi	infection	Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	Cl Residual: Total - mg/L																
	OL Month.Max	2.00	1.62	2.00	2.00	1.48	2.02	2.02	2.01	1.81	2.01	0.06	0.06			2.02	
	OL Month.Mean	1.18	1.11	0.53	0.90	0.89	0.65	0.98	0.62	1.16	1.04	0.06	0.06		0.76		
	OL Month.Min	0.00	0.24	0.00	0.00	0.01	0.00	0.00	0.03	0.49	0.06	0.06	0.06				0.00

Receiver Stream Data

Customized Monthly Report From 01/01/2024 to 12/31/2024 Facility Name: GERALDTON WASTEWATER TREATMENT FACILITY Receiver: Hardrock Creek to Kenogamisis Lake Facility Org Number: 5896 Facility Owner: Municipality: The Corporation of the Municipality of Greenstone Concise Devolution: 1902 Works: 110001649 Facility Classification: Class 2 Wastewater Treatment Total Design Capacity: 2500 m3/day



													2024	4	
1st West - Creek		May 2024		Jun 2024		Jul 2024		Aug 2024		Sep 2024	Total		Avg	Max	Min
E.Coli MPN - MPN															
Lab Month.Mean		14.00		126.00		33.00		64.00		133.00			74.00		
Total Ammonia Nitrogen: NH3 + NH4+ as N - mg/L															
Lab Month.Mean		0.01		0.02		0.03	1	0.04		0.05			0.03		
рн															
IH Month.Mean		7.37		6.82		7.16	1	6.14					6.87		
Total Phosphorus: TP - mg/L															
Lab Month.Mean		0.01		0.01		0.01	1	0.01		0.01			0.01		
Total Suspended Solids: TSS - mg/L															
Lab Month.Mean	<	3.00	<	3.00	<	3.00	<	3.00	<	3.00		<	3.00		
													202	4	
Downstream of Y - Creek		May 2024		Jun 2024		Jul 2024		Aug 2024		Sep 2024	Total		Avg	Max	Min
E.Coli MPN - MPN															
Lab Month.Mean		2.00		2.00		1.00		4.00		9.00			3.60		
рН															
IH Month.Mean		7.28		6.87		7.42		6.76					7.08		
Total Phosphorus: TP - mg/L															
Lab Month.Mean		0.03		0.03		0.03	1	0.04		0.04			0.03		
Total Suspended Solids: TSS - mg/L															
Lab Month.Mean		5.90		7.70	<	3.00	<	3.00	<	3.00		<	4.52		
													202	4	·
Barton Bay - Lake		May 2024		Jun 2024		Jul 2024		Aug 2024		Sep 2024	Total		Avg	Max	Min
Conductivity - μS/cm															
Lab Month.Mean		143.00		158.00		188.00		198.00		206.00			178.60		
E.Coli MPN - MPN															
Lab Month.Mean		1.00		1.00	<	1.00		4.00		6.00		<	2.60		
Total Ammonia Nitrogen: NH3 + NH4+ as N - mg/L															
Lab Month.Mean		0.01		0.02		0.05	1	0.05		0.02			0.03		
рН															
IH Month.Mean		7.29		6.68		7.15	+	6.41					6.88		
Total Phosphorus: TP - mg/L															
							1	Total Exec	ution	1: 15.87 minutes		_			L

Cı	ustomized Monthly Report Facility Name: GERALDTC TREATMENT FACILITY	ON WA	STEWATER	Facility O Facility O	rg Nu wner:	mber: 5896 : Municipality: 1	The Cor	poration of th	he	Works: 11000 Facility Classif	1649 icatio	on: Class 2 Wa	astew	vater Treatment	\cap	Ontari	o Clean Water Agency
Fr	rom 01/01/2024 to 12/31/2024 Receiver: Hardrock Creel	to Ker	nogamisis Lake	Municipa Sociale P	lity of	Greenstone				Total Design C	Capaci	ity: 2500 m3/	/day		\mathbf{i}	Agenc	e Ontarienne Des Eaux
	Lab Month.Mean		0.01	0.02		0.02		0.02		0.03				0.02			
	Total Suspended Solids: TSS - mg/L																
F	Lab Month.Mean	<	3.00	5.90	-	3.10		3.60		4.30	-		<	3.98			
														2024	4		
м	louth of Hardrock - Lake		May 2024	Jun 2024		Jul 2024		Aug 2024		Sep 2024		Total		Avg	Max	Min	
	Conductivity - μS/cm																
	Lab Month.Mean		182.00	203.00		208.00		229.00		238.00				212.00			
	E.Coli MPN - MPN																
	Lab Month.Mean		2.00	1.00		1.00		1.00		4.00				1.80			
	Total Ammonia Nitrogen: NH3 + NH4+ as N - mg/L																
	Lab Month.Mean		0.01	0.04		0.01		0.03		0.01				0.02			
	рн																
	IH Month.Mean		7.25	6.62		7.05		6.35						6.82			
	Total Phosphorus: TP - mg/L																
	Lab Month.Mean		0.02	0.03		0.03		0.04		0.04				0.03			
	Total Suspended Solids: TSS - mg/L																
F	Lab Month.Mean		8.70	4.10		3.30		3.80		3.30				4.64			
														2024	4		
м	lacleod Beach - Lake		May 2024	Jun 2024		Jul 2024		Aug 2024		Sep 2024		Total		Avg	Max	Min	
	Conductivity - µS/cm																
	Lab Month.Mean		171.00	176.00		184.00		188.00		186.00				181.00			
	E.Coli MPN - MPN																
	Lab Month.Mean	<	1.00 ·	< 1.00	<	1.00	<	1.00	<	1.00			<	1.00			
	Total Ammonia Nitrogen: NH3 + NH4+ as N - mg/L																
	Lab Month.Mean	<	0.01	0.02		0.01		0.04		0.06			<	0.03			
	рн																
	IH Month.Mean		7.31	7.07		7.24		7.20						7.21			
	Total Phosphorus: TP - mg/L																
	Lab Month.Mean		0.01	0.02		0.02		0.02		0.01				0.02			
	Total Suspended Solids: TSS - mg/L																
	Lab Month.Mean		4.10	4.30	<	3.00		3.40		3.90			<	3.74			

By-Pass Reports – 2024

Environmental Incident Report



System: Geraldton Waste	Water Treatment Plant.	M	MOE Works: 110001649							
Location: Geraldton WWTF	0	Re	eceiver: Ha	rdrock Cre	ek					
Start of Incident:	Date: April 11, 2024			Time:18:3	0					
□ Spill	Details/Cause of Inci	dent:								
⊠ Bypass	Bypass event due to	spring th	aw and he	avy rain						
□ Other										
Downstream Users □ Yes ⊠ No	Possible effects on re	eceiver, e	environmer	nt or downs	tream users: N/A					
Chlorination 🗵	Yes 🗆 No									
Corrective Actions: Initiate	ed bypass									
MOECC SAC called	Date: Apr 11, 2024	At 20:0	09 C	ontact: Bre	enda Capicciotti					
MOH – Northwestern Health Unit called	Date: Apr 12, 2024	At 10:0	5 C	ontact: Bra	aeden Payne					
Patti O'Handley called	Date: Apr 11, 2024	At 19:5	9 C	ontact: OC	WA					
called	Date: Apr 11, 2024	At 20:3	5 C	ontact: Bria	an Aaltonen					
Other:	Date:	at	С	ontact:						
Reference #: 1-5NZTBE	Operator I	Reporting	g Incident:	Filipe Jorge	e					
Termination:	e: April 12, 2024	-	Time 06:55	;	Duration: 12 hrs 25 min					
Approximate Volume (m ³) 465										
SAC called Date: April 1	2, 2024 at: 14	:35	Contac	t: Dylan	Wenzel					
Further Actions Required:	N/A									
Operator Reporting Termi	nation: Filipe Jorge									
MOECC SAC	Tel: 800 268-6060 Fax: 800 268-6061	(Comments							
MOH – Thunder Bay Health Unit	Tel: 1-807-625-5900 Tel: 807-623-7451									
(after hours)	rei: 807-625-5933 Tel: 807-624-1280									
				-						



Fax completed report: MOECC SAC, MOH, VP Operations/Corporate Office, Regional Manager, Geraldton Hub Office Group, PCTs, Client/Owner, ORO



OCWA PO Box 728 Geraldton, ON P0T 1M0

NOTIFICATION OF NON-COMPLIANCE

05/13/2024

Sam Shippam Drinking Water and Environmental Compliance Division

Re: Notification of Non-compliance with ECA Effluent Limit

This is a notification of non-compliance with an effluent limit for the Geraldton Wastewater Plant submitted in accordance with terms and conditions of Certificate of Approval 8151-7PDQX7, and provisions of the *Ontario Water Resources Act* and *Environmental Protection Act*.

The following effluent parameter(s) was/were exceeded as per 7(1) of the C of A:

Parameter	Date of Non- Compliance (yyyy-mm- dd)	Type of Limit	Type of Sample	Result (Specify Units)	Calculation Method	ECA Effluent Limit
Total Suspended Solids	2024-05-13	Monthly Average	Composite	31.4mg/L	Monthly Average	25 mg/L

Comments/Actions Taken:

High TSS due to high spring flows coming in and alum dosage not being adjusted quickly enough to accommodate the flows causing extra floc carryover. Alum is feed rates have been adjusted to accommodate flows.

Sincerely,

FILIPE JORGE Operations Supervisor/ORO Northwestern Ontario Hub

cc: Patti O'Handley, Senior Operations Manager Patrick Albert, General Manager Jeremy Drindak, Julia Vescio, David Hoffman, Process & Compliance Technicians Allyson Kirk, Safety, Process and Compliance Manager Brian Aaltonen, Client Representative



OCWA PO Box 728 Geraldton, ON P0T 1M0

NOTIFICATION OF NON-COMPLIANCE

01/09/2025

Sam Shippam Drinking Water and Environmental Compliance Division

Re: Notification of Non-compliance with ECA Effluent Limit

This is a notification of non-compliance with an effluent limit for the Geraldton Wastewater Plant submitted in accordance with terms and conditions of Certificate of Approval 8151-7PDQX7, and provisions of the *Ontario Water Resources Act* and *Environmental Protection Act*.

Parameter	Date of Non- Compliance (yyyy-mm- dd)	Type of Limit	Type of Sample	Result (Specify Units)	Calculation Method	ECA Effluent Limit
Total Suspended Solids	2024-12-31	Monthly Average	Composite	33.98 mg/L	Monthly Average	25 mg/L
CBOD	2024-12-31	Monthly Average	Composite	39.44 mg/L	Monthly Average	25 mg/L
CBOD Loading	2024-12-31	Monthly Average		66.35 kg/day	Monthly Average	62.5 kg/day

The following effluent parameter(s) was/were exceeded as per 7(1) of the C of A:

Comments/Actions Taken: Exceedance on TSS, CBOD, and CBOD loading do to mechanical failure on the clarifier. All parts have been ordered for repairs and will be fixed as soon as they arrive. Pumps have been installed in clarifier to maintain movement of sludge and to prevent freezing. SAC reference # 1FZPI8Z.

Sincerely,

Patti O'Handley Senior Operations Manager

cc: Fil Jorge, OIC/ORO Patrick Albert, General Manager Jeremy Drindak, Julia Vescio, David Hoffman, Process & Compliance Technicians Allyson Kirk, Safety, Process and Compliance Manager



Brian Aaltonen, Client Representative

Analyzer Verification/Calibration Summary







WOs 20831,20829,20828,20827,20825

Municipality of Greenstone Water Treatment Facilities

Instruments Calibrations

Completed: August 14,15 2024

By: Igor Riaboshapkin

Lakeside Process Controls **1165 Russell Street Thunder Bay, Ontario Canada P7B 5M6 Telephone: 1 (807) 624-2791** Fax: 1 (807) 623-7907





	Instruments List									
#	Device Type	Tag Name	Cal. Status	Notes						
		Geraldto	n							
1	Flowmeter	Grl Raw Water	Passed							
2	Flowmeter	Grl Treated Water	Passed							
3	Flowmeter	Grl Domestic Water	Passed							
4	Flowmeter	Grl WPC Plant 1 Final Effluent	Passed							
5	Flowmeter	Grl WPC Plant 2 Final Effluent	Passed							
6	Flowmeter	Grl Mckenzie LS Effluent	Passed							
7	Flowmeter	Grl WPC Influent	Passed							
8	Flowmeter	Grl RAS FIT-565	Passed							
9	Flowmeter	Grl RAS FIT-567	Passed							
10	Flowmeter	Grl WAS FIT-566	Passed							
11	Chlorine meter	Grl HH-CL	Passed							
12	Chlorine meter	Grl LAB-CL	Passed							
13	Turbidity meter	Grl LAB-TURB	Passed							
14	pH meter	Grl LAB-pH	Passed							
15	Chlorine meter	Grl HH-CL-2	Passed							





	Instruments List										
#	Device Type	Tag Name	Cal. Status	Notes							
16	Chlorine meter	Grl LAB-CL-2	Passed								
17	pH meter	Grl LAB-pH-2	Passed								

PassedInstruments:17Failed17Instruments:0Total Verified17

Biosolids Sludge Quality

ALS Canada Ltd.



CERTIFICATE OF ANALYSIS

Work Order	: TY2404216	Page	: 1 of 3
Client	: Ontario Clean Water Agency	Laboratory	: ALS Environmental - Thunder Bay
Contact	: Geraldton WPCP	Account Manager	: Christine Paradis
Address	: Operator Geraldton WPCP 320 Clarke	Address	: 1081 Barton Street
	Ave S.E PO Box 728		Thunder Bay ON Canada P7B 5N3
	Geraldton ON Canada P0T 1M0		
Telephone	:	Telephone	: +1 807 623 6463
Project	: 110001649	Date Samples Received	: 03-May-2024 14:42
PO	: 5896	Date Analysis	: 10-May-2024
		Commenced	
C-O-C number	:	Issue Date	: 12-May-2024 16:09
Sampler	:		
Site	: 110001649		
Quote number	: Geraldton WPCP/WWTP 2024		
No. of samples received	: 1		
No. of samples analysed	: 1		

This report supersedes any previous report(s) with this reference. Results apply to the sample(s) as submitted. This document shall not be reproduced, except in full.

This Certificate of Analysis contains the following information:

- General Comments
- Analytical Results

Additional information pertinent to this report will be found in the following separate attachments: Quality Control Report, QC Interpretive report to assist with Quality Review and Sample Receipt Notification (SRN).

Signatories

This document has been electronically signed by the authorized signatories below. Electronic signing is conducted in accordance with US FDA 21 CFR Part 11.

Signatories	Position	Laboratory Department
Nik Perkio	Inorganics Analyst	Metals, Waterloo, Ontario
Niki Goebel	Inorganics Analyst	Metals, Waterloo, Ontario

General Comments

The analytical methods used by ALS are developed using internationally recognized reference methods (where available), such as those published by US EPA, APHA Standard Methods, ASTM, ISO, Environment Canada, BC MOE, and Ontario MOE. Refer to the ALS Quality Control Interpretive report (QCI) for applicable references and methodology summaries. Reference methods may incorporate modifications to improve performance. Where a reported less than (<) result is higher than the LOR, this may be due to primary sample extract/digestate dilution and/or insufficient sample for analysis.

Where the LOR of a reported result differs from standard LOR, this may be due to high moisture content, insufficient sample (reduced weight employed) or matrix interference.

Please refer to Quality Control Interpretive report (QCI) for information regarding Holding Time compliance.

Key :

CAS Number: Chemical Abstracts Services number is a unique identifier assigned to discrete substances LOR: Limit of Reporting (detection limit).

Measurement Uncertainty: The reported uncertainties in this report are expanded uncertainties calculated using a coverage factor of 2, which gives a level of confidence of approximately 95%.

Surrogate: An analyte that is similar in behavior to target analyte (s), but that does not occur naturally in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery.

Unit	Description
mg/L	milligrams per litre

>: greater than.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED on SRN or QCI Report, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

<: less than.

Analytical Results

TY2404216-001 Sub-Matrix:Sludge

(Matrix: Water)

Client sample ID: WPCP Digested Sludge Client sampling date / time: 02-May-2024 14:05

Analyte	CAS Number	Result	LOR	Unit	Method/Lab	Prep Date	Analysis	QCLot
							Date	
Total Metals								
Aluminum, total	7429-90-5	945	2.0	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Antimony, total	7440-36-0	0.035	0.020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Arsenic, total	7440-38-2	0.828	0.020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Barium, total	7440-39-3	4.22	0.040	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Beryllium, total	7440-41-7	<0.020	0.020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Bismuth, total	7440-69-9	0.467	0.010	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Boron, total	7440-42-8	<2.0	2.0	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Cadmium, total	7440-43-9	0.0164	0.0020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Calcium, total	7440-70-2	600	100	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Chromium, total	7440-47-3	0.40	0.10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Cobalt, total	7440-48-4	<0.10	0.10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Copper, total	7440-50-8	22.8	0.20	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Iron, total	7439-89-6	386	10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Lead, total	7439-92-1	0.618	0.020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Lithium, total	7439-93-2	<0.20	0.20	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Magnesium, total	7439-95-4	86	10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Manganese, total	7439-96-5	9.15	0.10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Mercury, total	7439-97-6	0.00445	0.00050	mg/L	E508B/WT	10-May-2024	10-May-2024	1436495
Molybdenum, total	7439-98-7	0.087	0.010	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Nickel, total	7440-02-0	0.26	0.10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Phosphorus, total	7723-14-0	512	10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Potassium, total	7440-09-7	60	10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Selenium, total	7782-49-2	0.061	0.010	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Silver, total	7440-22-4	0.777	0.010	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Sodium, total	7440-23-5	78	10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Strontium, total	7440-24-6	1.75	0.0400	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Sulfur, total	7704-34-9	130	100	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Thallium, total	7440-28-0	<0.0020	0.0020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Tin, total	7440-31-5	0.388	0.020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Titanium, total	7440-32-6	1.41	0.060	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Tungsten, total	7440-33-7	<0.18	0.18	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Uranium, total	7440-61-1	0.0352	0.0020	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Vanadium, total	7440-62-2	0.14	0.10	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Zinc, total	7440-66-6	9.69	0.60	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494
Zirconium, total	7440-67-7	0.304	0.060	mg/L	E440B/WT	10-May-2024	10-May-2024	1436494

Please refer to the General Comments section for an explanation of any result qualifiers detected.

Please refer to the Accreditation section for an explanation of analyte accreditations.

REFER TO BACK	Released by:			Are samples for t		Are samples take	Drinking															ALS sample # (ALS use only)		ALS Lab Work	LSD:	PO / AFE:	Job / Project #:	ALS Client Cod		Contact:	Company:		Invoice To	Postal Code:	City/Province:	Street:		Phone:	Contact:	Company:	Report To					
PAGE FOR ALS LOCATIONS	Filipe Jorge Dat	SHIPMENT RELEAS	S	iuman consumption/ use?	S	n from a Regulated DW Syste	Water (DW) Samples ¹ (clie														WPCP Digested Sludge	(This de	Cample	Order # (ALS use only):	5896		110001649	B/QUOTE #: TY2	Project Infor			Copy of Invoice with Report	Same as Report To	POT 1MO	Geraldton, ON	320 Clarke Ave SE	Company address below will a	807-854-0877	Geraldton Waste Water Tre	OCWA	Contact and company nat	www.alsglobal.com				
AND SAMPLING INFORM	e: 03-N	SE (client use)		Ensure S		m?	nt use)															escription will appear of	Identification and/or	4114-				0230CWA1000029	mation			INO NO	ON D SEV D				ppear on the final report		alment		ne below will appear on the f					
MATION	1ay-24 Time: 9:00			Station acronym			Notes / Specify L							-								n the report)	Convinsion	4216																	Inal report				Q	
	Received by:	Z		and Short Name			imits for result ev (Ex															-	-	ALS Contact:	Location:	Requisitioner:	Major/Minor Code:	AFE/Cost Center:	0110	Email 2	Email 1 or Fax	Select Invoice Di		palbert@ocwa.com; [esabu@ocwa.com; ja bnavanookeesic@oo		Select Distributio	Compare Results t	Merge QC/QCI F	Select Report Fo					hain of Cus	
WH		ITTIAL SHIPMEN		s are included.			aluation by select cel COC only)														2-May-24	(dd-mmm-yy)	Dato	Dimen Mahmoo			•		and Gas Require		APNorthWest@o	stribution: 🖸 EM,	Invoice R	ab.results@greenstor	va.com: fiorge@ocwa	I	IN: S EMAIL	o Criteria on Report -	Reports with COA	rmat: SPDF	Reports / I	Ĩ	Canada Toli		tody (COC)	
ITE - LABORATOR	Date:	RECEPTION (A					ing from drop-dow														14:05	(hh:mm)	Time	Sampler:			Routing Code:	PO#	d Fields (client u		CW3.COM		ecipients	e.ca; katherine.alton(nwopct@oc.wa.com; .com: PO'Handlev@o	l		provide details below	ON ES 2340	a excer a edo	Recipients		Free: 1 800 668		/ Analytical	
Y COPY YELL		LS use only)					n below														Grab	Sample Type							ise)			FAX		greenstone.ca	owa.com:		×	if box checked	D WA	(DIGITAL)			9878		Request Fo	
	Time:		12	5	Cooler	Cooling		-	_	_					-		_	_			12	NU	M	IBER	0	F	:0	NT	AI	NE	R			Dat		Same d	L day [Routine					rm	
IENT CO	Нe		F	(N)ITIAI	Custody	Method		╞	-			_,	<u> </u>		+-	-					ת ת	Meta	ury	(e and Tin	Additi	ay [E2] #	E] If noce	P2] if neo	un and	[R] if rec			i			
)PY	peived				Seals			E																							Indicate		Fore	te Requi	onal fees	received	ved by 3	eved by :	wed by s	eived by	umarou					
	^{بر} ۲			RTEMP	Intact:	ÔNE	Ş	_									_		_										•		Filtered (li tests wi	ed for a	may app	by 10am	om M-F	Som M-F		3pm M-F	ınd Tim			Page	COC N	
		TINA	-	RATUR	Ð	Ē	MPLE	┝	-	+					-		+	-		_											F), Prese		th rush T	E&PT/	y to rush	- M-S -	100%	- 50%	- 20%	ns ou -	e (TAT)			Q	umber	
		L SHIF		rs c	5	Ø	RECE	-	+	-					+		-	-													Ived (P)	An	ATs reque	18	requests	200% ги	ush surc	ush surc	JSN SUTCT	rcharges	Reques	i	:		22	
	Date	MENT			VA	JE PACKS	IPT DE	Ľ	T			•																			or Filtere	alysis	sted, plea	F	: an weel	sh surcha	harge mi	harge mi	large mir	apply	ited				•	
		RECE			Sample		TAILS		_							_	_														id and Pr	Reque	ise contac		kends, st	lige.	nimum	nimum	mum				-			
	N	PTION		FINA	e Custo	FROZEN	(ALS u	┡	╀	-	· .				-		-			-		· · · · ·								╞	peviesa	st	rt your Ah	dd-mi	HIGIOTY IN		Тe								<u>–</u> 1	п
	~	(ALS U	┝		dy Sea		se only	\vdash	-						╈		┽													$\left \right $	F/P) beto		to confin	пт-уу	in chan		ephone								und	
	\mathcal{L}	se only		RTEMP	Is Intac		2																								¥		n availabi	hh:mm			: +1 80		ř				1 T		9r Ba	nmen
				ERATUR	Ģ	ING INI		L	+	_					-	+	-												<u> </u>				lity.	am/pn	WARNING I		623 64	B	ł				t T	Sad Sad		
UA)	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		┝		ß L	TIATED		┝	+	+		-		1		╉	+		-	+		EXT		NDED	s s			SE F	REC	ວຸບເ	RE				cien.		33		Ċ				P -	N Elocation Celocation		
2023 FRO	12				N/A			F	+	•	_				+	+	+					su	SP	ECTE	Di	HA2	ΔΕ	20 (600		stat							=	-			=	C	"		Í

.

ŀ