

February 2021

Mayor Renald Beaulieu and Council  
The Corporation of the Municipality of Greenstone  
P.O. Box 70  
GERALDTON, Ontario  
P0T 1M0

**Re: O. Regulation 170 - 2020 Section 11 Annual Reports for the:**

- **Beardmore Drinking-Water System**
- **Caramat Drinking-Water System**
- **Geraldton Drinking-Water System**
- **Longlac Drinking-Water System**
- **Nakina Drinking-Water System**

Ontario's Drinking-Water Systems Regulation (O.Reg. 170/03), made under the Safe Drinking Water Act, 2002, requires that the owner of a drinking water system prepare an annual report on the operation of the system and the quality of its water.

The annual report must cover the period of January 1<sup>st</sup> to December 31<sup>st</sup> in a year and *must be prepared not later than February 28<sup>th</sup>* of the following year. Pursuant to the legislative requirements, enclosed for your records are the *2020 Annual Reports* for the Municipality of Greenstone's Drinking-Water Systems.

Pursuant to the legislative requirements, Section 11 (6): the annual report must:

- (a) contain a brief description of the drinking-water system, including a list of water treatment chemicals used by the system during the period covered by the report;
- (b) summarize any reports made to the Ministry under subsection 18 (1) of the Act or section 16-4 of Schedule 16 during the period covered by the report;
- (c) summarize the results of tests required under this Regulation, or an approval or order, including an OWRA order, during the period covered by the report and, if tests required under this Regulation in respect of a parameter were not required during that period, summarize the most recent results of tests of that parameter;
- (d) describe any corrective actions taken under Schedule 17 or 18 during the period covered by the report;
- (e) describe any major expenses incurred during the period covered by the report to install, repair or replace required equipment; and

(f) in the case of a large municipal residential system or a small municipal residential system, include a statement of where a report prepared under Schedule 22 will be available for inspection under subsection 12 (4). O. Reg. 170/03, s. 11 (6)

In addition, Section 11 (7) gives the direction that a copy of an annual report for the system is given, without charge, to every person who requests a copy and be made available for inspection by any member of the public during normal business hours. The reports should be made available at the office of the municipality, or at a location that is accessible to the users of the water system.

Yours truly,



Patti O'Handley  
Senior Operations Manager  
Northwestern Ontario Regional Hub  
807-853-2356

Copy to: Mark Wright - CAO  
Brian Aaltonen – Director of Public Services  
Operations Staff – Beardmore WTP  
Operations Staff – Caramat WTP  
Operations Staff – Geraldton WTP  
Operations Staff – Longlac WTP  
Operations Staff – Nakina Well Supply

# 2020 Section 11 Annual Report

## Beardmore Drinking Water System

February 2021

Prepared by the



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



**Section 11 ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	<b>210001264</b>
<b>Drinking-Water System Name:</b>	Beardmore Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Greenstone
<b>Drinking-Water System Category:</b>	<b>Large Municipal Residential Drinking Water-System</b>
<b>Period being reported:</b>	January 1 – December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p><b>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <table border="1" style="width: 100%;"> <tr> <td> <b>Geraldton Ward Office (Administration)</b>                      1800 Main Street                      Geraldton, ON P0T 1M0  <b>Beardmore Ward Office</b>                      285 Main Street                      Beardmore, ON P0T 1G0                 </td> </tr> </table>	<b>Geraldton Ward Office (Administration)</b> 1800 Main Street Geraldton, ON P0T 1M0 <b>Beardmore Ward Office</b> 285 Main Street Beardmore, ON P0T 1G0	<p><b><u>Complete for all other Categories.</u></b></p> <p><b>Number of Designated Facilities served:</b></p> <table border="1" style="width: 100%;"> <tr> <td>N/A</td> </tr> </table> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</b></p> <p><b>Number of Interested Authorities you report to:</b></p> <table border="1" style="width: 100%;"> <tr> <td>N/A</td> </tr> </table> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</b></p>	N/A	N/A
<b>Geraldton Ward Office (Administration)</b> 1800 Main Street Geraldton, ON P0T 1M0 <b>Beardmore Ward Office</b> 285 Main Street Beardmore, ON P0T 1G0				
N/A				
N/A				

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	



**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

Yes [ ] No [ ]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

**Public access/notice via the web**

**Public access/notice via Government Office (Municipal)**

**Public access/notice via a newspaper**

**Public access/notice via Public Request**

**Public access/notice via a Public Library**

**Public access/notice via other method** \_\_\_\_\_

**Describe your Drinking-Water System**

The raw water is pumped from the Blackwater River by the low lift pumps into the packaged treatment plant tank, which is a Graver monoplant treatment unit; a type of solids contact clarifier. The flocculation, sedimentation, and filtration processes are all contained within the packaged plant. Aluminum sulfate is added to the raw water as a coagulant after the low lift pumps and prior to the treatment unit. Two polymers are used to assist with flocculation depending on seasonal conditions. These are injected into the raw water immediately before the treatment unit.

The floc settles onto the tube settlers in the clarifier. The water then passes through a two-compartment dual media (sand and anthracite) filter. Once through the filters, the water is chlorinated with sodium hypochlorite. Carus 8500 Ortho-polyphosphate is used for corrosion control and caustic soda is used for pH adjustment. These three chemicals are injected into the piping between the filter and reservoir. The reservoir is located beneath the process floor and is divided into two compartments having a combined capacity of 682 m3.

Two high lift pumps deliver the finished water to the distribution system and a third high lift pump delivers water under fire flow conditions.

A 160-kW-diesel generator provides standby power to the WTP.

**List all water treatment chemicals used over this reporting period**

- Caustic Soda (Sodium Hydroxide)
- Sodium Hypochlorite
- Nalco-2 (Sodium Aluminate)
- Nalco 8170 polymer



# Ontario Drinking-Water Systems Regulation O. Reg. 170/03

- Aluminum Sulphate
- Carus 8500

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Install	Repair	Replace	Description	Expense
N/A	N/A	N/A	N/A	N/A

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A	N/A	N/A	N/A	N/A	N/A

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	51	0 – 46	>18 – >2420	N/A	N/A
Treated	51	0 – 0	0 – 0	51	0 – 1
Distribution	94	0 – 0	0 – 0	27	0 – 6

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of	Range of Results
--	-----------	------------------

*NOTE: For continuous monitors use 8760 as the number of samples.*

	Grab Samples	(min #)-(max #)
<b>Turbidity*</b>		
Raw (before filter)	8760	0.0 – 9.99 NTU
Treated	8760	0.0 – 1.99 NTU
<b>Chlorine*</b>		
Treated	8760	0.00 – 4.99
Distribution	366	0.40 – 2.72
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A	N/A	N/A	N/A	N/A

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	13-Jan-2020	<0.6	µg/L	No
<b>Arsenic</b>	13-Jan-2020	<1.0	µg/L	No
<b>Barium</b>	13-Jan-2020	10.0	µg/L	No
<b>Boron</b>	13-Jan-2020	<50.0	µg/L	No
<b>Cadmium</b>	13-Jan-2020	<0.1	µg/L	No
<b>Chromium</b>	13-Jan-2020	<1.0	µg/L	No
<b>*Lead</b>	Refer to Summary Table Below			
<b>Mercury</b>	13-Jan-2020	<0.1	µg/L	No
<b>Selenium</b>	13-Jan-2020	<1.0	µg/L	No
<b>Sodium</b>	22-Jul-2019	17.3	mg/L	No
<b>Uranium</b>	13-Jan-2020	<2.0	µg/L	No
<b>Fluoride</b>	22-Jul-2019	<0.02	mg/L	No
<b>Nitrite</b>	13-Jan-2020	<0.010	mg/L	No
	20-Apr-2020	<0.010	mg/L	No
	06-Jul-2020	<0.010	mg/L	No



	05-Oct-2020	<0.010	mg/L	No
<b>Nitrate</b>	13-Jan-2020	0.078	mg/L	No
	20-Apr-2020	0.128	mg/L	No
	06-Jul-2020	0.049	mg/L	No
	05-Oct-2020	<0.02	mg/L	No

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
<b>Plumbing</b>	Sampling not required as per Ont. Regulation 170	-	-
<b>Distribution</b>	2	1 – 1	0

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Alachlor (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Atrazine</b>	13-Jan-2020	<0.10	µg/L	No
<b>Atrazine &amp; Metabolites</b>	13-Jan-2020	<0.20	µg/L	No
<b>Azinphos-methyl (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Benzene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Benzo(a)pyrene (ug/L) - TW</b>	13-Jan-2020	<0.005	µg/L	No
<b>Bromoxynil (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Carbaryl (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Carbofuran (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Carbon Tetrachloride (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Chlorpyrifos (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Diazinon (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Dicamba (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>1,2-Dichlorobenzene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>1,4-Dichlorobenzene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>1,2-Dichloroethane (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>1,1-Dichloroethylene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Dichloromethane (Methylene Chloride) (ug/L) - TW</b>	13-Jan-2020	<5.0	µg/L	No
<b>2,4-Dichlorophenol (ug/L) - TW</b>	13-Jan-2020	<0.3	µg/L	No
<b>2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Diclofop-methyl (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Dimethoate (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Diquat (ug/L) - TW</b>	13-Jan-2020	<1.0	µg/L	No
<b>Diuron (ug/L) - TW</b>	13-Jan-2020	<1.0	µg/L	No





<b>Glyphosate (ug/L) - TW</b>	13-Jan-2020	<5.0	µg/L	No
<b>Haloacetic acids (HAA)*</b> (NOTE: show latest annual average)	05-Oct-2020 2020 Average	51.2 57.8	µg/L	No
<b>Malathion (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Metolachlor (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Metribuzin (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Monochlorobenzene (Chlorobenzene) (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Paraquat (ug/L) - TW</b>	13-Jan-2020	<1.0	µg/L	No
<b>PCB (ug/L) - TW</b>	13-Jan-2020	<0.035	µg/L	No
<b>Pentachlorophenol (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Phorate (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Picloram (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Prometryne (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Simazine (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>THM</b> (NOTE: show latest annual average)	05-Oct-2020 2020 Average	92.9 74.1	µg/L µg/L	No
<b>Terbufos (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>Tetrachloroethylene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>2,3,4,6-Tetrachlorophenol (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Triallate (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Trichloroethylene (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>2,4,6-Trichlorophenol (ug/L) - TW</b>	13-Jan-2020	<0.5	µg/L	No
<b>Trifluralin (ug/L) - TW</b>	13-Jan-2020	<0.1	µg/L	No
<b>Vinyl Chloride (ug/L) - TW</b>	13-Jan-2020	<0.2	µg/L	No
<b>MCPA</b>	13-Jan-2020	<0.2	µg/L	No

\*Parameter exceedance not reportable until 2020

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
2020 THM - Running Annual Average (RAA)	74.1	µg/L	N/A
2020 HAA – Running Annual Average (RAA)	57.8	µg/L	N/A

Parameter exceedance not reportable until 2020

# 2020 Section 11 Annual Report

## Caramat Drinking Water System

February 2021

Prepared by the



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



**Section 11 ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	220000184
<b>Drinking-Water System Name:</b>	Caramat Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Greenstone
<b>Drinking-Water System Category:</b>	Small Municipal Residential Drinking Water-System
<b>Period being reported:</b>	January 1 – December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ X ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be</p> <div style="border: 1px solid black; padding: 5px;"> <p><b>Geraldton Ward Office (Administration)</b> 1800 Main Street Geraldton, ON POT 1M0</p> <p><b>Longlac Ward Office</b> 105 Hamel Avenue Longlac, ON POT 2A0</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to:  <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [ ] No [ ]



Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office (Municipal)

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

The treatment process generally consists of pre-ozonation, filtration through the multi-stage slow sand filter, primary chlorination, storage, and secondary chlorination.

The filtration system consists of a 75.2 m<sup>3</sup>/day pre-packaged, two-train, multi-stage filtration system designed and manufactured by MS Filter Inc. The two-train roughing filter, slow sand filter and granular activated carbon (GAC) contractor are all contained within one overall filter tank. The ozone generation and contactor equipment is separate from the filter tank.

Primary disinfection is achieved using a 12% sodium hypochlorite solution injected into the raw water, downstream of the filtration system, by means of two (duty/stand-by) chemical metering pumps. The necessary chlorine contact time is achieved within the two 57 m<sup>3</sup> reservoirs. The reservoirs provide the necessary minimum contact time for adequate disinfection as well as equalization and emergency water storage as per MOE guidelines.

Two high lift pumps (duty and stand-by) draw treated water from the reservoirs to the distribution system.

One backwash pump also draws treated water from the reservoirs and is used to backwash the filtration system.

The free chlorine residual of the treated water is monitored continuously by an online analyzer, and recorded in the PLC.

A magnetic flow meter measures the treated water flow to the distribution system. This information is recorded in the PLC.

Secondary disinfection is achieved using a 12% sodium hypochlorite solution injected into the high lift pump discharge header by means of two (duty and stand-by) chemical metering pumps.

A 60-kW-diesel generator in a stand alone container provides standby power to the WTP.

In November 2009, an oxygen concentrator system was installed and put into operation.



**List all water treatment chemicals used over this reporting period**

- Sodium Hypochlorite 12%
- Oxygen (generated on site)
- Ozone (generated on site)
- Granular activated carbon (GAC)

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Install	Repair	Replace	Description	Expense
N/A	N/A	N/A	N/A	N/A

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
N/A	N/A	N/A	N/A	N/A	N/A

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	N/A	N/A	N/A	N/A	N/A
Treated	N/A	N/A	N/A	N/A	N/A
Distribution	52	0	0	49	0-3

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity*</b>		
Raw	96	0.06 – 2.7 NTU
Filter #1	8760	0.01 – 1.99 NTU
Filter #2	8760	0.00 – 1.99 NTU
<b>Chlorine*</b>		
Treated	8760	0.00 – 2.44
Distribution	109	0.50 – 1.88
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples.*

*\* Turbidity & chlorine Min/Max (lows/highs) are due to planned maintenance and not plant upset.*

**NOTE: Record the unit of measure if it is *not* milligrams per litre.**

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
July 4, 2011 Municipal Drinking Water Licence (MDWL)#225-101	Nitrosodimethylamine (NDMA) Quarterly	07-Jan-2020	0.00082	µg/L
		06-Apr-2020	0.00117	µg/L
		06-Jul-2020	0.00151	µg/L
		05-Oct-2020	0.00081	µg/L



July 4, 2011 Municipal Drinking Water Licence (MDWL)#225-101	Trihalomethanes (THM's) Monthly	07-Jan-2020	51.60	µg/L
		03-Feb-2020	39.00	µg/L
		02-Mar-2020	29.30	µg/L
		06-Apr-2020	33.60	µg/L
		11-May-2020	43.80	µg/L
		01-Jun-2020	48.20	µg/L
		06-Jul-2020	28.30	µg/L
		04-Aug-2020	41.70	µg/L
		01-Sept-2020	63.10	µg/L
		05-Oct-2020	42.90	µg/L
		02-Nov-2020	21.00	µg/L
01-Dec-2020	27.70	µg/L		

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Antimony</b>	02-Jan-2020	<0.6	µg/L	No
<b>Arsenic</b>	02-Jan-2020	<1.0	µg/L	No
<b>Barium</b>	02-Jan-2020	14.0	µg/L	No
<b>Boron</b>	02-Jan-2020	<50.0	µg/L	No
<b>Cadmium</b>	02-Jan-2020	<0.1	µg/L	No
<b>Chromium</b>	02-Jan-2020	<1.0	µg/L	No
<b>*Lead</b>	Refer to Summary Table Below			
<b>Mercury</b>	02-Jan-2020	<0.1	µg/L	No
<b>Selenium</b>	02-Jan-2020	<1.0	µg/L	No
<b>Sodium</b>	06-Feb-2017	6.95	mg/L	No
<b>Uranium</b>	02-Jan-2020	<2.0	µg/L	No
<b>Fluoride</b>	06-Feb-2017	<0.02	mg/L	No
<b>Nitrite</b>	07-Jan-2020	<0.010	mg/L	No
	06-Apr-2020	<0.010	mg/L	No
	06-Jul-2020	<0.010	mg/L	No
	05-Oct-2020	<0.010	mg/L	No
<b>Nitrate</b>	07-Jan-2020	0.233	mg/L	No
	06-Apr-2020	0.213	mg/L	No
	06-Jul-2020	0.114	mg/L	No
	05-Oct-2020	0.238	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	Sampling not required as per Ont. Regulation 170	-	-
Distribution	2	1 - 1	0

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	02-Jan-2018	<0.1	µg/L	No
Atrazine + N-dealkylated metabolites	02-Jan-2018	<0.2	µg/L	No
Azinphos-methyl	02-Jan-2018	<0.1	µg/L	No
Benzene	02-Jan-2018	<0.5	µg/L	No
Benzo(a)pyrene	02-Jan-2018	<0.01	µg/L	No
Bromoxynil	02-Jan-2018	<0.2	µg/L	No
Carbaryl	02-Jan-2018	<0.2	µg/L	No
Carbofuran	02-Jan-2018	<0.2	µg/L	No
Carbon Tetrachloride	02-Jan-2018	<0.2	µg/L	No
Chlorpyrifos	02-Jan-2018	<0.1	µg/L	No
Diazinon	02-Jan-2018	<0.1	µg/L	No
Dicamba	02-Jan-2018	<0.2	µg/L	No
1,2-Dichlorobenzene	02-Jan-2018	<0.5	µg/L	No
1,4-Dichlorobenzene	02-Jan-2018	<0.5	µg/L	No
1,2-Dichloroethane	02-Jan-2018	<0.5	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	02-Jan-2018	<0.5	µg/L	No
Dichloromethane (methylene chloride)	02-Jan-2018	<5.0	µg/L	No
2,4 Dichlorophenol	02-Jan-2018	<0.3	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	02-Jan-2018	<0.2	µg/L	No
Diclofop-methyl	02-Jan-2018	<0.2	µg/L	No
Dimethoate	02-Jan-2018	<0.1	µg/L	No
Diquat	02-Jan-2018	<1.0	µg/L	No
Diuron	02-Jan-2018	<1.0	µg/L	No





<b>Glyphosate</b>	02-Jan-2018	<5.0	µg/L	No
<b>Haloacetic acids (HAA)</b> (NOTE: show latest annual average)	05-Oct-2020 2020 Average	50.30 60.93	µg/L	No
<b>Malathion</b>	02-Jan-2018	<0.1	µg/L	No
<b>Metolachlor</b>	02-Jan-2018	<0.1	µg/L	No
<b>Metribuzin</b>	02-Jan-2018	<0.1	µg/L	No
<b>Monochlorobenzene</b>	02-Jan-2018	<0.5	µg/L	No
<b>Paraquat</b>	02-Jan-2018	<1.0	µg/L	No
<b>Pentachlorophenol</b>	02-Jan-2018	<0.5	µg/L	No
<b>Phorate</b>	02-Jan-2018	<0.1	µg/L	No
<b>Picloram</b>	02-Jan-2018	<0.2	µg/L	No
<b>Polychlorinated Biphenyls(PCB)</b>	02-Jan-2018	<0.035	µg/L	No
<b>Prometryne</b>	02-Jan-2018	<0.1	µg/L	No
<b>Simazine</b>	02-Jan-2018	<0.1	µg/L	No
<b>THM</b> (NOTE: show latest annual average)	01-Dec-2020 2020 Average	27.70 39.18	µg/L µg/L	No No
<b>Terbufos</b>	02-Jan-2018	<0.2	µg/L	No
<b>Tetrachloroethylene</b>	02-Jan-2018	<0.5	µg/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	02-Jan-2018	<0.5	µg/L	No
<b>Triallate</b>	02-Jan-2018	<0.1	µg/L	No
<b>Trichloroethylene</b>	02-Jan-2018	<0.5	µg/L	No
<b>2,4,6-Trichlorophenol</b>	02-Jan-2018	<0.5	µg/L	No
<b>Trifluralin</b>	02-Jan-2018	<0.1	µg/L	No
<b>Vinyl Chloride</b>	02-Jan-2018	<0.2	µg/L	No

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

<b>Parameter</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Date of Sample</b>
2020 HAA – Running Annual Average (RAA)	60.93	µg/L	N/A

# 2020 Section 11 Annual Report

## Geraldton Drinking Water System

February 2021

Prepared by the



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



**Section 11 ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	210000292
<b>Drinking-Water System Name:</b>	Geraldton Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Greenstone
<b>Drinking-Water System Category:</b>	Large Municipal Residential Drinking Water-System
<b>Period being reported:</b>	January 1 – December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p><b>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;"> <p><b>Geraldton Ward Office (Administration)</b> 1800 Main Street Geraldton, ON POT 1M0</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p><b>Number of Designated Facilities served:</b></p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">N/A</div> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</b></p> <p><b>Number of Interested Authorities you report to:</b></p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">N/A</div> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</b></p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

Drinking Water System Name	Drinking Water System Number
N/A	N/A

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**



Yes [ ] No [ ]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office (Municipal)

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

Cecile Lake is the sole source of supply for the Geraldton water system. The surface water is conveyed by gravity through two (2) coarse screens to the intake well and low lift pumping chamber.

Prior to entering the treatment plant, Alum (aluminum sulphate) and polymer are added for coagulation. Potassium permanganate is added to the raw water for manganese removal as required.

The raw water passes through stages of mixing, flocculation, sedimentation with the aid of tube settlers and passes through a filter of mixed media consisting of anthracite, sand and gravel.

Disinfection is provided by injecting chlorine gas into the filtered water before it enters the storage reservoirs.

Three high lift pumps deliver water to the distribution system.  
A 200-kW-diesel generator provides standby power to the WTP.

**List all water treatment chemicals used over this reporting period**

- Aluminum Sulphate A-10
- Magnafloc LT-20 polymer
- Potassium Permanganate
- Chlorine Gas

**Were any significant expenses incurred to?**

- Install required equipment  
 Repair required equipment  
 Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Install	Repair	Replace	Description	Expense
X		X	3HP decant pump	\$15,000
X		X	40HP high lift pump	\$50,000
X		X	40HP low lift pump	\$50,000

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
27-Feb-2020	Loss of pressure to three businesses and 25 homes. Call MOH spoke with Torsten Schulz. BWA issued to home owners and businesses.	-	-	Collect 1 bacteriological sample.	02-Mar-2020
04-Mar-2020	Loss of pressure to 20 homes in Olde Road area. Call MOH and spoke with Melissa Syrja. BWA issued to home owners.	-	-	Collect 1 bacteriological sample.	07-Mar-2020
26-Mar-2020	Loss of pressure to 15 homes and 1 business. Call MOH, BWA issued to affected area.	-	-	Collect 1 bacteriological sample.	30-Mar-2020
15-Apr-2020	Exceeded lead limit at hydrant.	13.3	ug/L	Flush hydrant and resample.	27-Apr-2020



30-Apr-2020	Loss of pressure due to hydrant replacement/repair affecting 6 businesses. BWA issued for affected area.	-	-	Collect 1 bacteriological sample.	05-May-2020
15-Jul-2020	Loss of pressure to 18 homes. Installing new 2" line to the fire hall from the 12" main line.	-	-	Flush main, collect 1 bacteriological sample.	17-Jul-2020
25-Aug-2020	Loss of pressure due to hydrant relocation at school affecting 25 homes. BWA issued for affected area.	-	-	Flush main, collect 1 bacteriological sample.	28-Aug-2020
20-Oct-2020	Loss of pressure to 4 homes, 1 nurses residence and hospital. Located on 4 <sup>th</sup> Ave SW between 4 <sup>th</sup> St West and 5 <sup>th</sup> St West. Installing new valve and hydrant for the Hospital.	-	-	Collect 1 bacteriological sample.	23-Oct-2020
18-Dec-2020	Loss of pressure to 1 home due to repair of a broken 6" water main and changing out a fire hydrant. Flushing after repair was done.	-	-	Collect 1 bacteriological sample.	30-Dec-2020

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw</b>	53	0 – 3	0 – 201	N/A	N/A
<b>Treated</b>	52	0 – 0	0 – 0	52	0 – 1
<b>Distribution</b>	157	0	0	46	0 – 7

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity*</b>		
<b>Raw</b>	250	0.09 – 5.37 NTU
<b>Filter #1</b>	8760	0.00 – 1.81 NTU
<b>Filter #2</b>	8760	0.00 – 3.00 NTU
<b>Chlorine*</b>		
<b>Treated</b>	8760	0.00 – 4.99
<b>Distribution</b>	403	0.10 – 2.06
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples.*

*\* Turbidity & chlorine Min/Max (lows/highs) are due to planned maintenance and not plant upset.*

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
July 4, 2011 Municipal Drinking Water Licence 225-104	Suspended Solids (Composite)	08-Jun-2020	4.8	mg/L
		13-Jul-2020	<3.0	mg/L
	Frequency: Monthly	11-Aug-2020	<3.0	mg/L
		01-Sept-2020	<3.0	mg/L
	Location: Point of Discharge to Yvonne Lake			
Note: Samples can only be collected when conditions permit. Winter conditions prevent sampling as the discharge location is frozen.		Average Annual Concentration for 2020	3.45	mg/L

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	13-Jan-2020	<0.6	µg/L	No
Arsenic	13-Jan-2020	<1.0	µg/L	No
Barium	13-Jan-2020	<10.0	µg/L	No
Boron	13-Jan-2020	<50.0	µg/L	No
Cadmium	13-Jan-2020	<0.1	µg/L	No
Chromium	13-Jan-2020	<1.0	µg/L	No
*Lead	Refer to Summary Table Below			
Mercury	13-Jan-2020	<0.1	µg/L	No
Selenium	13-Jan-2020	<1.0	µg/L	No
Sodium	09-Jan-2019	17.2	mg/L	No
Uranium	13-Jan-2020	<2.0	µg/L	No
Fluoride	09-Jan-2019	<0.02	mg/L	No
Nitrite	13-Jan-2020	<0.010	mg/L	No
	07-Apr-2020	<0.010	mg/L	No
	13-Jul-2020	<0.010	mg/L	No
	05-Oct-2020	<0.010	mg/L	No
Nitrate	13-Jan-2020	0.037	mg/L	No
	07-Apr-2020	0.226	mg/L	No
	13-Jul-2020	0.055	mg/L	No
	05-Oct-2020	<0.02	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	Sampling not required as per Ont. Regulation 170	-	-
Distribution	5	1 – 13.3 µg/L	1



**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	13-Jan-2020	<0.1	µg/L	No
Atrazine	13-Jan-2020	<0.2	µg/L	No
Atrazine & Metabolites	13-Jan-2020	<0.1	µg/L	No
Azinphos-methyl	13-Jan-2020	<0.1	µg/L	No
Benzene	13-Jan-2020	<0.5	µg/L	No
Benzo(a)pyrene	13-Jan-2020	<0.005	µg/L	No
Bromoxynil	13-Jan-2020	<0.2	µg/L	No
Carbaryl	13-Jan-2020	<0.2	µg/L	No
Carbofuran	13-Jan-2020	<0.2	µg/L	No
Carbon Tetrachloride	13-Jan-2020	<0.2	µg/L	No
Chlorpyrifos	13-Jan-2020	<0.1	µg/L	No
Diazinon	13-Jan-2020	<0.1	µg/L	No
Dicamba	13-Jan-2020	<0.2	µg/L	No
1,2-Dichlorobenzene	13-Jan-2020	<0.5	µg/L	No
1,4-Dichlorobenzene	13-Jan-2020	<0.5	µg/L	No
1,2-Dichloroethane	13-Jan-2020	<0.5	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	13-Jan-2020	<0.5	µg/L	No
Dichloromethane	13-Jan-2020	<5.0	µg/L	No
2-4 Dichlorophenol	13-Jan-2020	<0.3	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	13-Jan-2020	<0.2	µg/L	No
Diclofop-methyl	13-Jan-2020	<0.2	µg/L	No
Dimethoate	13-Jan-2020	<0.1	µg/L	No
Diquat	13-Jan-2020	<1.0	µg/L	No
Diuron	13-Jan-2020	<1.0	µg/L	No
Glyphosate	13-Jan-2020	<5.0	µg/L	No
Haloacetic acids (HAA)* (NOTE: show latest annual average)	05-Oct-2020 2020 Average	45.3 27.6	µg/L	No
Malathion	13-Jan-2020	<0.1	µg/L	No
Metolachlor	13-Jan-2020	<0.1	µg/L	No
Metribuzin	13-Jan-2020	<0.1	µg/L	No
Monochlorobenzene	13-Jan-2020	<0.5	µg/L	No
Paraquat	13-Jan-2020	<1.0	µg/L	No
Pentachlorophenol	13-Jan-2020	<0.5	µg/L	No
Phorate	13-Jan-2020	<0.1	µg/L	No
Picloram	13-Jan-2020	<0.2	µg/L	No
Polychlorinated Biphenyls(PCB)	13-Jan-2020	<0.035	µg/L	No
Prometryne	13-Jan-2020	<0.1	µg/L	No
Simazine	13-Jan-2020	<0.1	µg/L	No
THM (NOTE: show latest annual average)	05-Oct-2020 2020 Average	66.5 44.4	µg/L µg/L	No No



Terbufos	13-Jan-2020	<0.2	µg/L	No
Tetrachloroethylene	13-Jan-2020	<0.5	µg/L	No
2,3,4,6-Tetrachlorophenol	13-Jan-2020	<0.5	µg/L	No
Triallate	13-Jan-2020	<0.1	µg/L	No
Trichloroethylene	13-Jan-2020	<0.5	µg/L	No
2,4,6-Trichlorophenol	13-Jan-2020	<0.5	µg/L	No
Trifluralin	13-Jan-2020	<0.1	µg/L	No
Vinyl Chloride	13-Jan-2020	<0.2	µg/L	No
MCPA	13-Jan-2020	<0.2	µg/L	No

\*Parameter exceedance not reportable until 2020

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

Parameter	Result Value	Unit of Measure	Date of Sample
Lead on Hydrant	13.3	ug/L	06-Apr-2020

# 2020 Section 11 Annual Report

## Longlac Drinking Water System

February 2021

Prepared by the



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



**Section 11 ANNUAL REPORT**

<b>Drinking-Water System Number:</b>	220000264
<b>Drinking-Water System Name:</b>	Longlac Water Treatment Plant
<b>Drinking-Water System Owner:</b>	The Corporation of the Municipality of Greenstone
<b>Drinking-Water System Category:</b>	Large Municipal Residential Drinking Water-System
<b>Period being reported:</b>	January 1 – December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <table border="1" style="width: 100%;"> <tr> <td>                 Geraldton Ward Office (Administration)                  1800 Main Street                  Geraldton, ON POT 1M0                  Longlac Ward Office                  105 Hamel Avenue                  Longlac, ON POT 2A0             </td> </tr> </table>	Geraldton Ward Office (Administration) 1800 Main Street Geraldton, ON POT 1M0 Longlac Ward Office 105 Hamel Avenue Longlac, ON POT 2A0	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <input style="width: 100px;" type="text" value="N/A"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to:  <input style="width: 100px;" type="text" value="N/A"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
Geraldton Ward Office (Administration) 1800 Main Street Geraldton, ON POT 1M0 Longlac Ward Office 105 Hamel Avenue Longlac, ON POT 2A0		

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?



Yes [ ] No [ ]

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office (Municipal)

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

The Longlac Water Treatment Plant (WTP), located on Park Street, draws raw water from Long Lake. The WTP is a package plant, consisting of two Graver Reactors/Filters. Treatment includes coagulation, flocculation, and sedimentation with the aid of tube settlers, filtration, corrosion control and disinfection. This plant has a design capacity of 6,050 m<sup>3</sup>/day. The WTP presently serves a population of approximately 1750 persons within the community and 500 persons within two First Nations. The WTP was designed with the anticipation that the community would experience growth.

Long Lake is the sole source of supply for the Longlac water system. A surface water intake with 245 m of 450 mm diameter intake piping through two course screens convey water by gravity to the intake well, and the low lift pumping chamber. Alum is the coagulant and the flocculation aid is Nalclear 8181 (polymer), they are added to the raw water between the low lift pumps and the treatment unit. The water is then pumped to the *Graver Reactors/Filters Treatment Unit*. The Reactivators are solids contact clarifiers combining coagulation, flocculation, and sedimentation in one unit. The water is flocculated, and the floc settled out using tube settlers in the solids contact clarifier and by maintaining a sludge blanket. The water then passes through a two-compartment dual media (sand and anthrafil) filter.

Once through the filters the water is chlorinated with chlorine gas; and Carus 8500 orthophosphate is added for corrosion control. The water then enters a treated water reservoir. The reservoir, located beneath the process floor, is divided into three compartments with a total capacity of 705 m<sup>3</sup>. Three high lift pumps deliver the finished water to the distribution system. The elevated storage tank with a capacity of 2273 m<sup>3</sup> provides emergency storage and fire flow. Pressure is controlled by a pilot operated Pressure Relief Valve.

Wastewater from the filter backwash and clarifier blowdown is collected in a wastewater storage tank, and then pumped to the municipal sanitary sewer system.

A 200-kW-diesel generator provides standby power to the entire WTP.

List all water treatment chemicals used over this reporting period

- Aluminum Sulphate
- Chlorine Gas
- Carus 8500
- Nalclear 8181 Polymer

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Install	Repair	Replace	Description	Expense
N/A	N/A	N/A	N/A	N/A

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
20-May-2020	Loss of coagulation (alum) due to power failure. GFCI breaker tripped.	-	-	Restore power, operate in manual mode to waste to restore clarifier. Replace receptacle and rewired alum panel through UPS	21-May-2020

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	54	0 – 16	1 – 1200	N/A	N/A
Treated	54	0 – 0	0 – 0	53	0 – 2
Distribution	124	0 – 0	0 – 0	55	0 – 295

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity*</b>		
Raw	236	0.4 – 11.0 NTU
Filter #1	8760	0.0 – 2.99 NTU
Filter #2	8760	0.0 – 2.99 NTU
<b>Chlorine*</b>		
Treated	8760	0.0 – 4.99
Distribution	367	0.32 – 1.84
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples.*

*\* Turbidity & chlorine Min/Max (lows/highs) are due to planned maintenance and not plant upset.*

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A	N/A	N/A	N/A	N/A

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	09-Jan-2020	<0.6	µg/L	No
Arsenic	09-Jan-2020	<1.0	µg/L	No
Barium	09-Jan-2020	11.0	µg/L	No
Boron	09-Jan-2020	<50.0	µg/L	No
Cadmium	09-Jan-2020	<0.1	µg/L	No
Chromium	09-Jan-2020	<1.0	µg/L	No
*Lead	Refer to Summary Table Below			
Mercury	09-Jan-2020	<0.1	µg/L	No
Selenium	09-Jan-2020	<1.0	µg/L	No
Sodium	11-Jan-2017	3.7	mg/L	No
Uranium	09-Jan-2020	<2.0	µg/L	No
Fluoride	11-Jan-2017	<0.02	mg/L	No
Nitrite	07-Jan-2020	<0.01	mg/L	No
	07-Apr-2020	<0.01	mg/L	No
	07-Jul-2020	<0.01	mg/L	No
	07-Oct-2020	<0.01	mg/L	No
Nitrate	07-Jan-2020	0.079	mg/L	No
	07-Apr-2020	0.104	mg/L	No
	07-Jul-2020	0.042	mg/L	No
	07-Oct-2020	0.034	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems



**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	Sampling not required as per Ont. Regulation 170	-	-
Distribution	4	1 – 1.9 ug/L	0

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	09-Jan-2020	<0.1	µg/L	No
Atrazine	09-Jan-2020	<0.2	µg/L	No
Atrazine & Metabolites	09-Jan-2020	<0.1	µg/L	No
Azinphos-methyl	09-Jan-2020	<0.1	µg/L	No
Benzene	09-Jan-2020	<0.5	µg/L	No
Benzo(a)pyrene	09-Jan-2020	<0.005	µg/L	No
Bromoxynil	09-Jan-2020	<0.2	µg/L	No
Carbaryl	09-Jan-2020	<0.2	µg/L	No
Carbofuran	09-Jan-2020	<0.2	µg/L	No
Carbon Tetrachloride	09-Jan-2020	<0.2	µg/L	No
Chlorpyrifos	09-Jan-2020	<0.1	µg/L	No
Diazinon	09-Jan-2020	<0.1	µg/L	No
Dicamba	09-Jan-2020	<0.2	µg/L	No
1,2-Dichlorobenzene	09-Jan-2020	<0.5	µg/L	No
1,4-Dichlorobenzene	09-Jan-2020	<0.5	µg/L	No
1,2-Dichloroethane	09-Jan-2020	<0.5	µg/L	No
1,1-Dichloroethylene (vinylidene chloride)	09-Jan-2020	<0.5	µg/L	No
Dichloromethane	09-Jan-2020	<5.0	µg/L	No
2-4 Dichlorophenol	09-Jan-2020	<0.3	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	09-Jan-2020	<0.2	µg/L	No
Diclofop-methyl	09-Jan-2020	<0.2	µg/L	No
Dimethoate	09-Jan-2020	<0.1	µg/L	No
Diquat	09-Jan-2020	<1.0	µg/L	No
Diuron	09-Jan-2020	<1.0	µg/L	No
Glyphosate	09-Jan-2020	<5.0	µg/L	No



<b>Haloacetic acids (HAA)</b> (NOTE: show latest annual average)	07-Oct-2020 2020 Average	29.7 38.3	µg/L	No
<b>Malathion</b>	09-Jan-2020	<0.1	µg/L	No
<b>Metolachlor</b>	09-Jan-2020	<0.1	µg/L	No
<b>Metribuzin</b>	09-Jan-2020	<0.1	µg/L	No
<b>Monochlorobenzene</b>	09-Jan-2020	<0.5	µg/L	No
<b>Paraquat</b>	09-Jan-2020	<1.0	µg/L	No
<b>Pentachlorophenol</b>	09-Jan-2020	<0.5	µg/L	No
<b>Phorate</b>	09-Jan-2020	<0.1	µg/L	No
<b>Picloram</b>	09-Jan-2020	<0.2	µg/L	No
<b>Polychlorinated Biphenyls(PCB)</b>	09-Jan-2020	<0.035	µg/L	No
<b>Prometryne</b>	09-Jan-2020	<0.1	µg/L	No
<b>Simazine</b>	09-Jan-2020	<0.1	µg/L	No
<b>THM</b> (NOTE: show latest annual average)	07-Oct-2020 2020 Average	36.1 38.0	µg/L µg/L	No No
<b>Terbufos</b>	09-Jan-2020	<0.2	µg/L	No
<b>Tetrachloroethylene</b>	09-Jan-2020	<0.5	µg/L	No
<b>2,3,4,6-Tetrachlorophenol</b>	09-Jan-2020	<0.5	µg/L	No
<b>Triallate</b>	09-Jan-2020	<0.1	µg/L	No
<b>Trichloroethylene</b>	09-Jan-2020	<0.5	µg/L	No
<b>2,4,6-Trichlorophenol</b>	09-Jan-2020	<0.5	µg/L	No
<b>Trifluralin</b>	09-Jan-2020	<0.1	µg/L	No
<b>Vinyl Chloride</b>	09-Jan-2020	<0.2	µg/L	No
<b>MCPA</b>	09-Jan-2020	<0.2	µg/L	No

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A	N/A	N/A	N/A

# 2020 Section 11 Annual Report

## Nakina Drinking Water System

February 2021

Prepared by the



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**



Section 11 ANNUAL REPORT

Drinking-Water System Number:	220000200
Drinking-Water System Name:	Nakina Well Supply
Drinking-Water System Owner:	The Corporation of the Municipality of Greenstone
Drinking-Water System Category:	Large Municipal Residential Drinking Water-System
Period being reported:	January 1 – December 31, 2020

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [ X ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Geraldton Ward Office (Administration) 1800 Main Street Geraldton, ON P0T 1M0</p> <p>Nakina Ward Office 200 Centre Avenue Nakina, ON P0T 2H0</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</p> <p>Number of Interested Authorities you report to:  <div style="border: 1px solid black; padding: 2px; display: inline-block;">N/A</div> </p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</p>
--	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
N/A	N/A

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes [ ] No [ ]



Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office (Municipal)

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method \_\_\_\_\_

### Describe your Drinking-Water System

The Nakina Water Supply System is supplied by two (2) groundwater wells. The water supply aquifer utilized by the Corporation of the Municipality of Greenstone – Nakina Ward lies within an esker complex (significant sand and gravel deposit). These deposits are common throughout the area and the most extensive of these features trend southwesterly through the Township. Composed primarily of gravelly sand, this broad belt stretches approximately 4 km in width and 60 km in length. The two wells are located approximately 72 m from the southeastern shore of Rounds Lake.

The wells are housed within the same building, and a common header delivers water to the reservoir beneath the high lift pumping station. The water is chlorinated using sodium hypochlorite at the entry point to the reservoir. The high lift and fire pumps draw water from the reservoir for the delivery to the system.

Wells #1 & #2 are each capable of supplying 18.9 L/s, and were designed to be operated simultaneously for a total of 37.9 L/s. Fire flow and emergency storage is supplied from the reservoir. The facility presently serves a population of approximately 700 persons and was designed with the anticipation of growth within the community.

A 60 kW diesel generator provides standby power for the well pumps and a 200 kW diesel generator provides power for the chemical feed system and the high lift and fire pumps.

In a hydro geological study conducted by KGS Group, the wells were identified **as not** under the direct influence of surface water.

### List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

Install	Repair	Replace	Description	Expense
X			Low lift pump installation	\$13,885.96

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
16-Apr-2020	Lead exceedance on hydrant	12.5	ug/L	Resample	28-Apr-2020

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
<b>Raw</b>					
Well 1	51	0 – 0	0 – 0	N/A	N/A
Well 2	51	0 – 0	0 – 0	N/A	N/A
<b>Treated</b>	52	0 – 0	0 – 0	51	0 – 1
<b>Distribution</b>	104	0 – 0	0 – 0	28	0 – 2

**Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.**



	Number of Grab Samples	Range of Results (min #)-(max #)
<b>Turbidity*</b>		
Raw Well #1	72	0.16 – 0.38 NTU
Raw Well #2	166	0.027 – 0.82 NTU
Treated	8760	0.00 – 9.88 NTU
<b>Chlorine*</b>		
Treated	8760	0.00 – 3.81
Distribution	353	0.45 – 1.18
<b>Fluoride</b> (If the DWS provides fluoridation)	N/A	N/A

*NOTE: For continuous monitors use 8760 as the number of samples.*

*\* Turbidity & chlorine Min/Max (lows/highs) are due to planned maintenance and not plant upset.*

**NOTE:** Record the unit of measure if it is **not** milligrams per litre.

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A	N/A	N/A	N/A	N/A

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	03-Jan-2020	<0.6	µg/L	No
Arsenic	03-Jan-2020	<1.0	µg/L	No
Barium	03-Jan-2020	14.0	µg/L	No
Boron	03-Jan-2020	<50.0	µg/L	No
Cadmium	03-Jan-2020	<0.1	µg/L	No
Chromium	03-Jan-2020	<1.0	µg/L	No
*Lead	Refer to Summary Table Below			
Mercury	03-Jan-2020	<0.1	µg/L	No
Selenium	03-Jan-2020	<1.0	µg/L	No
Sodium	09-Dec-2019	12.5	mg/L	No
Uranium	03-Jan-2020	<2.0	µg/L	No
Fluoride	09-Dec-2019	0.051	mg/L	No
Nitrite	02-Mar-2020	<0.01	mg/L	No
	04-May-2020	<0.01	mg/L	No
	13-Jul-2020	<0.01	mg/L	No
	05-Oct-2020	<0.01	mg/L	No



			mg/L	No
<b>Nitrate</b>	02-Mar-2020	0.122	mg/L	No
	04-May-2020	0.161	mg/L	No
	13-Jul-2020	0.245	mg/L	No
	05-Oct-2020	0.16	mg/L	No

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

<b>Location Type</b>	<b>Number of Samples</b>	<b>Range of Lead Results (min#) – (max #)</b>	<b>Number of Exceedances</b>
<b>Plumbing</b>	Sampling not required as per Ont. Regulation 170	-	-
<b>Distribution</b>	5	0 – 12.5 ug/L	1

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

<b>Parameter</b>	<b>Sample Date</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Exceedance</b>
Alachlor	03-Jan-2018	<0.1	µg/L	No
Atrazine + N-dealkylated metabolites	03-Jan-2018	<0.2	µg/L	No
Azinphos-methyl	03-Jan-2018	<0.1	µg/L	No
Benzene	03-Jan-2018	<0.5	µg/L	No
Benzo(a)pyrene	03-Jan-2018	<0.01	µg/L	No
Bromoxynil	03-Jan-2018	<0.2	µg/L	No
Carbaryl	03-Jan-2018	<0.2	µg/L	No
Carbofuran	03-Jan-2018	<0.2	µg/L	No
Carbon Tetrachloride	03-Jan-2018	<0.2	µg/L	No
Chlorpyrifos	03-Jan-2018	<0.1	µg/L	No
Diazinon	03-Jan-2018	<0.1	µg/L	No
Dicamba	03-Jan-2018	<0.2	µg/L	No
1,2-Dichlorobenzene	03-Jan-2018	<0.5	µg/L	No
1,4-Dichlorobenzene	03-Jan-2018	<0.5	µg/L	No
1,2-Dichloroethane	03-Jan-2018	<0.5	µg/L	No





1,1-Dichloroethylene (vinylidene chloride)	03-Jan-2018	<0.5	µg/L	No
Dichloromethane	03-Jan-2018	<0.5	µg/L	No
2-4 Dichlorophenol	03-Jan-2018	<0.3	µg/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	03-Jan-2018	<0.2	µg/L	No
Diclofop-methyl	03-Jan-2018	<0.2	µg/L	No
Dimethoate	03-Jan-2018	<0.1	µg/L	No
Diquat	03-Jan-2018	<1.0	µg/L	No
Diuron	03-Jan-2018	<1.0	µg/L	No
Glyphosate	03-Jan-2018	<5.0	µg/L	No
Haloacetic acids (HAA)* (NOTE: show latest annual average)	23-Oct-2019 2019 Average	9.6 7.7	µg/L	No
Malathion	03-Jan-2018	<0.1	µg/L	No
Metolachlor	03-Jan-2018	<0.1	µg/L	No
Metribuzin	03-Jan-2018	<0.1	µg/L	No
Monochlorobenzene	03-Jan-2018	<0.5	µg/L	No
Paraquat	03-Jan-2018	<1.0	µg/L	No
Pentachlorophenol	03-Jan-2018	<0.5	µg/L	No
Phorate	03-Jan-2018	<0.1	µg/L	No
Picloram	03-Jan-2018	<0.2	µg/L	No
Polychlorinated Biphenyls(PCB)	03-Jan-2018	<0.035	µg/L	No
Prometryne	03-Jan-2018	<0.1	µg/L	No
Simazine	03-Jan-2018	<0.1	µg/L	No
THM (NOTE: show latest annual average)	23-Oct-2019 2019 Average	12.8 12.1	µg/L µg/L	No No
Terbufos	03-Jan-2018	<0.2	µg/L	No
Tetrachloroethylene	03-Jan-2018	<0.5	µg/L	No
2,3,4,6-Tetrachlorophenol	03-Jan-2018	<0.5	µg/L	No
Triallate	03-Jan-2018	<0.1	µg/L	No
Trichloroethylene	03-Jan-2018	<0.5	µg/L	No
2,4,6-Trichlorophenol	03-Jan-2018	<0.5	µg/L	No
2-methyl-4-chlorophenoxyacetic acid (MCPA)	03-Jan-2018	<0.2	ug/L	No
Trifluralin	03-Jan-2018	<0.1	µg/L	No
Vinyl Chloride	03-Jan-2018	<0.2	µg/L	No

\*Parameter exceedance not reportable until 2020

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Lead on Hydrant	12.5	ug/L	08-Apr-2020